



RICHARD BRAGA
OIL SALES & SERVICES REPRESENTATIVE

SAFETY-KLEEN CORP.
50 A BRIGHAM STREET
MARLBORO, MA 01752
508/481-3116 FAX 508/485-7638

The Doctor Inc.
Annual inspection

I Richard Braga on Dec. 11th inspected the inground
safety tank at The Doctor Inc. 2 Eastern Rd. Acton ma.
In such tank found the level to be 10"
and the content to be 0 WATER

owner Peter Murphy

inspector Richard Braga

**ACTON BOARD OF HEALTH
ANNUAL INSPECTION
OF HAZARDOUS MATERIALS PERMIT HOLDER**

Facility Name: The Doctor
Contact Person: Rick Murphy
Address: 2 Eastern Rd
Telephone: 263-2773
Type of Business: auto repair

Housekeeping:

- ☐ is area *clean*: yes no
- ☐ are *spills* present: yes no
- ☐ is there *appropriate storage* of materials: yes no
- ☐ are materials and wastes kept *separate*: yes no
- ☐ are *spill cleanup materials* available: yes no
- ☐ do hazardous materials have *secondary containment*: yes no
- ☐ are materials and wastes *labeled*: yes no - label oil filter barrel

Safety:

- ☐ are *MSDSs* available on site: yes no
- ☐ is employee *personal protective equipment* available on site: yes no gloves, goggles
- ☐ are employees *trained* in hazardous materials handling: yes no
- ☐ are *emergency procedures* posted: yes no

Site Management:

- ☐ are *wastes removed* by a licensed hauler: yes no Safety Klein
- ☐ are *floor drains* present in any area with hazardous materials or waste: yes no
- ☐ are *sinks* present in any area with hazardous materials or waste: yes no
- ☐ is testing of *septic system* necessary: yes no
- ☐ does *site plan* on file reflect current arrangement: yes no
- ☐ any *UST (underground storage tank)* present: yes no
- ☐ if UST present, is it *alarmed*: yes no alarm on tight tank

Comments:

neat
organized

Areas Needing Immediate Attention:

CORRECT BY ONE MONTH FROM TODAY

label used oil filter barrel

Health Representative Signature/Date:

Sharon Walker Mastenbrook 12-11-94

Permit Holder Contact Person Signature/Date:

Paul F. Murphy

EMERGENCY SPILL PROCEDURES

Police 263-2911

Fire 263-9191

Safety Kleen 978-481-3116

1. SMALL SPILL PROCEDURES:

Under 25 Gallons

- a) Apply speedy dry.**
- b) Place used speedy dry in barrel and store with hazardous waste.**
- c) Have removed by Safety Kleen**

2. LARGE SPILL PROCEDURES:

Over 25 Gallons

- a) Surround spill with pillows to create berm**
- b) Call your hazwaste hauler's emergency number**
- c) Notify board of health**

3. Spills under 25 gallons

- The Facility Operator or his employee shall apply a commercial absorbent, such as speedy dry to the spill area.**
- When all spilled material has been absorbed, the exhausted absorbent shall be placed in a tightly sealed container.**
- When the container has reached its capacity, a licensed waste disposal contractor shall be contacted to remove and dispose of the contaminated material.**

4. Spills over 25 gallons(or spill that flows onto public or private property)

- Notify Acton Fire Department.**
- Notify**
 - a. Spill clean up contractor**
 - b. Acton Board of Health**
 - c. Mass. Dept of Environmental Protection**
 - d. US Environmental Protection Agency**
 - e. Acton Water Department(if spill has entered a catch basin)**
- When each of the above have been made aware of the situation, the facility operator and/or his employee(s) shall make every effort to contain the spill until the clean-up contractor arrives.**

5. Suspected underground storage tank leak

- Arrange for testing of the suspect tank(s).**
- If leak test is positive see below.**

6. Verified underground storage tank leak

- Remove the leaking tank from service(shut off the dispenser serving the**

- leaking tank)
- Notify Acton Fire Department/Health Department

CONTACT:

- a. Acton Board of Health
- b. Clean-up Contractor
- c. Mass. Dept. of Environmental Protection
- d. US Environmental Protection Agency
- e. Under Water Department